






01 Estudio fotométrico
FOT-01 Esc. 1:50

Schedule

Symbol	Label	QTY	Manufacturer	Catalog	Description	Number Lamps	Lamp Output	LLF	Input Power
	A	6	MAGG	L6591-110	BL U EMP. 1200 25W 4000K	1	2300	0.9	25
	B	47	MAGG	L6656-110	LUNA 9 11W IP 65	1	1100	0.9	11
	C	1	MAGG	L5457-510	GAMMA LED 1200 S SIST. DE EMER. 100-305V 4000K GR TX	1	3660	0.9	29
	D	3	MAGG	L7320-91M	EP 120 46° 2700K	1	570	0.9	8

02 Schedule
FOT-01 S/E

Statistics						
Description	Symbol	Avg	Max	Min	Max/Min	Avg/Min
Aseo		129 lux	148 lux	93 lux	1.6:1	1.4:1
Sanitario		260 lux	306 lux	192 lux	1.6:1	1.4:1
Sanitario 01		214 lux	231 lux	205 lux	1.1:1	1.0:1
Sanitario 02		172 lux	172 lux	172 lux	1.0:1	1.0:1
Usos múltiples 01		378 lux	464 lux	228 lux	2.0:1	1.7:1
Usos múltiples 02		373 lux	472 lux	263 lux	1.8:1	1.4:1
Vestíbulo		682 lux	1086 lux	156 lux	7.0:1	4.4:1
Almacén		211.13 lux	293.83 lux	92.20 lux	3.2:1	2.3:1

03 Statistics
FOT-01 S/E

Power Statistics				
Description	# Luminaires	Total Watts	Area	Density
DPEA usos múltiples 02	9	99 W	16 m²	6 W/m²
DPEA usos múltiples 01	12	132 W	26 m²	5 W/m²

04 Power statistics
FOT-01 S/E